



Table of Contents

Commercial Load Calculations

Part A – General

- General Requirements
- Conductor Ampacity [Article 100]6
- Conductor Overcurrent Protection [240.4]
- Voltages [220.2(A)]
- Rounding an Ampere [220.2(B)]

Part B – Loads

- Air-Conditioning
- Dryers
- Electric Heat
- Kitchen Equipment
- Laundry Equipment
- Lighting – Demand Factors [Table 220.3(A) and 220.11]
- Lighting Without Demand Factors [Table 220.3(A), 215.2(A)(1) and 230.42].
- Lighting – Miscellaneous
- Multioutlet Receptacle Assembly [220.3(B)(8)]
- Receptacles VA Load [220.13]
- Banks and offices – General Lighting and Receptacles
- Signs [220.3(B)(6) and 600.5]
- Neutral Calculations [220.22]

Part C – Load Calculation Examples

- Marina [555.12]
- Mobile/Manufactured Home Park [550.31]
- Recreational Vehicle Park [551.73]
- Restaurant – Optional Method [220.36]
- School – Optional Method [220.34]
- Service Demand Load Using the Standard Method
- Bank (120/240V, 1Ø)
- Office Building (480Y/277V, 3Ø).
- Restaurant - Standard Load Calculation (208Y/120V, 3Ø)

Calculations Questions